

CERTIFICATE

Issued to:
Applicant:
Enjoy Innovation Ltd
1812 Fo Tan Industrial Centre 26-28
Au Pu Wan Street
Shatin N.T., Hong Kong

Licensee:
Enjoy Innovation Ltd
1812 Fo Tan Industrial Centre 26-28
Au Pu Wan Street
Shatin N.T., Hong Kong

Product : 4-pole socket outlets
Trade name(s) : POWER
Type(s)/model(s) : pwp16ci, pwp16co and pwp16coip

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard(s) NEN 1020:2019, NEN-IEC 60884-1:2019, NEN-IEC 60884-1:2019/A1:2019 and NEN-IEC 60884-1:2019/A2:2019
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 6056753


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on 20 July 2021 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-119723

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



M. Triulzi
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: 4-pole socket outlets
Trade name(s)	: POWER
Type(s)/model(s)	: pwp16ci, pwp16co and pwp16coip
Rated current	: 16 A
Rated voltage	: 440/230 V
Earthing	: with earthing contact
Terminals	: screw terminal
Cover	: singular screw fixed made of thermoplastic
Design	: without shutter
Markings	: - type reference and electrical ratings on the base - trade name and type reference for the cover in this part

Product data – type pwp16ci

Method of mounting	: flush-type
Standard sheet	: VIII - form B2
Degree of protection	: IP20

Product data – type pwp16co

Method of mounting	: surface-type
Standard sheet	: VIII - form A2
Degree of protection	: IP20

Product data – type pwp16coip

Method of mounting	: surface-type
Standard sheet	: VIII - form A2
Degree of protection	: IP44 (lid close)

TESTS**Test requirements**

NEN 1020:2019
NEN-IEC 60884-1:2019
NEN-IEC 60884-1:2019/A1:2019
NEN-IEC 60884-1:2019/A2:2019

Test result

The test results are laid down in DEKRA test file 224828800, 225761300.

Additional information

This certificate replaces certificate No. 71-116124 which we hereby declare invalid.

Conclusion

The examination proved that all requirements were met.